

Certificate



for European Product Safety
Intertek

Reference No. 1613320

Switches/disconnectors

Type designation DC LB216, DC LB225, DC LB232

Certificate holder **Salzer Electronics Limited**
Unit 2, Chinnamadam Palayam,
Coimbatore-641 019,
INDIA

The product complies with the standard(s) EN 60947-1:2007+A1+A2
EN 60947-3:2009+A1+A2

Date of expiry 22 June 2021

EU Directive information According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed


Bo Berglöf

Date 22 June 2016
Page 1 of 3



**Intertek
Appendix**

Reference No. 1613320

Technical data

Type designation: DC LB216
 BRAND name: **saizer**
 Rated voltage (V): 1500VDC, 1000VDC, 700VDC, 500VDC
 Rated current (A): 16A (1500VDC), 20A (1000VDC, 700VDC, 500VDC)
 Frequency (Hz): DC
 Pole No.: 4P
 IP-Class: IP20
 Product information : Icw=1000A/1s
 Icm=800A (1500VDC)
 Icm=1000A (1000VDC, 700VDC, 500VDC)
 Ui=1500VDC, Uimp=8kV
 Cat.: DC-21B, DC-PV2

Type designation: DC LB225
 BRAND name: **saizer**
 Rated voltage (V): 1500VDC, 1000VDC, 700VDC, 500VDC
 Rated current (A): 23A (1500VDC), 25A (1000VDC, 700VDC, 500VDC)
 Frequency (Hz): DC
 Pole No.: 4P
 IP-Class: IP20
 Product information : Icw=1000A/1s
 Icm=800A (1500VDC)
 Icm=1000A (1000VDC, 700VDC, 500VDC)
 Ui=1500VDC, Uimp=8kV
 Cat.: DC-21B, DC-PV2

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek
Appendix

Reference No. 1613320

Type designation:	DC LB232
BRAND name:	salzer
Rated voltage (V):	1500VDC, 1000VDC, 700VDC, 500VDC
Rated current (A):	32A (1500VDC), 40A (1000VDC, 700VDC, 500VDC)
Frequency (Hz):	DC
Pole No.:	4P
IP-Class:	IP20
Product information :	lcw=1000A/1s lcm=800A (1500VDC) lcm=1000A (1000VDC, 700VDC, 500VDC) Ui=1500VDC, Uimp=8kV Cat.: DC-21B, DC-PV2

Manufacturing site(s)	Salzer Electronics Limited Unit 2, Chinnamadam Palayam, Coimbatore-641 019, INDIA
-----------------------	--

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

If the product is to be marketed in different European countries, it must be provided with a certified plug appropriate for each country.

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed	 Bo Berglöf	Date	22 June 2016
--------	---	------	--------------

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.